

CENTRAL ELECTRICITY REGULATORY COMMISSION

MINUTES OF MEETING OF THE COORDINATION FORUM HELD ON 17TH AUGUST, 2009

1.0 The following were present:

1. Dr. Pramod Deo, Chairperson, ... **In Chair**
2. Mr. Rakesh Nath, Chairman, CEA (Ex-officio Member, CERC)
3. Mr. R. Krishnamoorthy, Member, CERC
4. Mr. S. Jayaraman, Member, CERC
5. Mr. V.S. Verma, Member, CERC
6. Mr. V. Ramakrishna, Member(PS), CEA
7. Mr. Sudhir Kumar, JS, MOP
8. Mr. S.K. Chaturvedi, CMD, PGCIL
9. Mr. Alok Kumar, Secretary, CERC
10. Mr. Pankaj Batra, Chief (E)
11. Mr. Ravinder, Chief Engineer, CEA
12. Mr. I.J. Kapoor, Director, NTPC
13. Mr. R.K. Madan, Director, Adani Enterprises Ltd.
14. Mr. S.K. Soonee, Exec. Dir (SO), PGCIL
15. Mr. I.S. Jha, ED, PGCIL
16. Mr. M.S. Babu, ED, NHPC
17. Mr. A Basu Roy, NTPC

2.0 **Agenda Item No. 1; Presentation by NLDC on instances of congestion on inter-state transmission system:**

A detailed presentation was made by Shri S.K. Soonee, a copy of which is enclosed (Annex.I). It was highlighted in the presentation that major reason for congestion was voltage problem. Some delays in commissioning of strengthening schemes also came up for discussions. There was a broad consensus that CTU should come up with appropriate solutions for addressing the increased demand for reactive power. The funds available in UI pool account and the congestion revenue could be utilized for providing such ancillary services. CMD, PGCIL assured to take further action in this regard. The need for reviewing the present charges being levied for reactive power was also felt.

3.0 Agenda Item No. 2: Presentation by NLDC on the need and various aspects of further narrowing the permissible frequency band:

A presentation was made by Mr. S.K. Soonee, Executive Director, PGCIL, a copy of which is enclosed (Annex.II). It was highlighted in the presentation that low frequency situations are also resulting in sub-standard grid voltages. After the discussions, it was generally felt that there was a need to further narrow down the permissible frequency range from 49.5 Hz to 50.3 Hz w.e.f. January, 2010 and from 49.8 Hz to 50.2 Hz w.e.f. January, 2011. The Forum also felt that appropriate measures including disconnection from the level of RLDC needed to be separately established in order to enforce the statutory provisions regarding permissible frequency and overdrawals. One of the ways could also be to set penal UI charges beyond the permissible frequency level at much higher level. There was also a suggestion that public awareness campaign could also be useful in this regard.

4.0 Agenda Item No. 3: Issues relating to development of transmission lines through competitive bidding

After discussions, it was felt that the principles and methodologies for determining tariff for the period after expiry of first licence period should be evolved and the same should be in public domain, so that the bidders take into account these guidelines while submitting their bids. It was also suggested that the model TSA could be amended to provide for that the transmission service provider shall approach the regulatory commission for renewal of licence and determination of tariff well in advance say, two years before the expiry of first licence period.

5.0 Any other issue: CMD, PGCIL mentioned that there are some issues being faced in respect of payment guarantee and bankability of transmission projects being taking up for providing long-term access and connectivity. The Forum desired that PGCIL may make detailed presentation in this regard in the next meeting.

The meeting ended with vote of thanks to the Chair.








.....

Coordination Forum
4th meeting


17th Aug-2009

Outline

- **System parameters in NR: June to Aug 09**
- **Experience of Congestion in NR during 2008**
 - Imposition of congestion charge on 31st Jan-08 & 15th Sep-08
- **Experience of Congestion in SR during 2008**
- **Experience of Congestion in NR during 2009**
 - Southwest monsoons
 - Low voltage
 - Transmission constraint due to tower damage
 - Simultaneous multiple element outage
 - Transmission line loading in NR
 - Short-term Open Access in NR
 - Inter regional flow
 - Transfer Capability declarations
- **Summary- Congestion in India**
- **UI regulations- is it adequate to handle congestion ?**
- **Concerns and suggestions**




Load in Northern region in Jul 2008 and Jul 2009




Northern Regional Consumption (5 years)

Increase of 76 MU/day in July 2009 compared to July 2008
12.5 % higher as compared to Jul-08



Haryana Energy consumption (5 years)



Increase in energy consumption recorded in other States in Jul-09 w.r.t Jul-08

21 % in J&K
7 % in H.P.


>19 % in Uttarakhand
>4 % in Rajasthan

18 % in Uttar Pradesh,
~ 3 % in Punjab

>10 % in Delhi


Thermal generation in NR (5 years)

Thermal Generation in the Northern Region increased by 46 MU/Day
In July 2009 compared to July 2008



400 kV Dadri voltage in Jul 2008

and Jul 2009
Average 11 kV drop in voltage in Jul 2009



Transmission system augmentation 08-09

- 400 kV Bareilly-Moradabad-II
- LILO of 400 kV Bassi-Hisar at Bhiwadi
- 400 kV RAPS-C-Kankroli I & II
- 400 kV Kishenpur-Baghlihar-I & II
- 400 kV Kota-Merta D/C
- 400 kV Ratangarh-Merta

Generation Capacity addition (NR)

Punjab: 250 MW
J & K: 450 MW
Rajasthan: 375 MW

| State | Maximum MW demand met during July-2009 | |
|-------------|--|-----------------------|
| Punjab | 7368 | 17 th July |
| Haryana | 5618 | 22 nd July |
| Rajasthan | 4963 | 1 st July |
| Delhi | 4371 | 8 th July |
| U P | 8139 | 19 th July |
| Uttarakhand | 1313 | 27 th July |
| H P | 940 | 16 th July |
| J&K | 1457 | 14 th July |
| Regional | 30675 | 9 th July |




Northern Region- Year 2008


- By and large congestion free
 - Benefits of past transmission system augmentation in 2007-08
 - Good Southwest monsoons in NR
 - Low or negative load growth rate
- Congestion charge in accordance with CERC regulations was kicked in by NRLDC only on two occasions
 - 31st January 2008, 1400 hrs to 1830 hrs
 - 15th September 2008, 0300 hrs to 0800 hrs

Imposition of Congestion Charge in NR on 31st Jan-08


TTC,ATC,NR Import Schedule and Actual NR import on 31-01-2008




**Antecedent
condition
31st Jan-08
Morning hours**




Voltage Profile on 31-01-2008 Morning in NR Grid



Voltage Profile on 31-01-2008




**Improvement in voltage profile
subsequent to imposition of
congestion charge**



31st Jan-08, 1400 hrs- 1830 hrs

Imposition of Congestion charge in NR 15th September 2008, 0300 hrs to 0800 hrs



Exactly a week later, NTPC Dadri complex plus HVDC Rihand Dadri bipole tripped During night hours. Low load conditions in NR averted a major blackout.

Congestion charges in NR during 1400-1830 Hrs of 31-Jan-08

ABSTRACT OF CONGESTION CHARGES FOR THE PERIOD - 28/01/2008 TO 03/02/2008

(During 1400 to 1830 Hrs of 31.01.2008)

(All figs. in Rs. Lakh)

| Utilities and Amount payable | | : | Utilities and Amount receivable | |
|------------------------------|-----------------|----------|---------------------------------|-----------------|
| J & K | 17.64474 | : | U.P. | 31.27593 |
| NHPC | 14.54484 | : | HARYANA | 8.25168 |
| RAJASTHAN | 14.00064 | : | NTPC | 7.32345 |
| PUNJAB | 10.25229 | : | NATHPA JHAKRI HEP | 5.45754 |
| UTTARAKHAND | 4.17780 | : | DELHI | 0.98244 |
| CHANDIGARH | 3.57531 | : | RAILWAYS | 0.06522 |
| H.P. | 3.39426 | | | |
| TEHRI HEP | 2.94264 | | BALANCE | 17.17626 |
| Total | 70.53252 | : | Total | 70.53252 |

Congestion charges in NR during 0300-0800 Hrs of 15-Sep-08


| REVISED ABSTRACT OF CONGESTION CHARGES FOR THE PERIOD - 15/09/2008 TO 21/09 | | | | |
|---|------------------|----------|---------------------------------|------------------|
| (During 0300 to 0800 Hrs of 15.09.2008) | | | | |
| (All figs. in Rs. Lakh) | | | | |
| Utilities and Amount payable | | : | Utilities and Amount receivable | |
| U.P. | 71.13870 | : | NTPC | 0.25002 |
| PUNJAB | 38.28792 | | | |
| J & K | 22.40385 | | | |
| RAJASTHAN | 9.44025 | | | |
| HARYANA | 6.73287 | | | |
| H.P. | 4.44246 | | | |
| RAILWAYS | 1.67727 | | | |
| UTTARAKHAND | 1.55286 | | | |
| DELHI | 0.62559 | | | |
| CHANDIGARH | 0.47061 | | | |
| NHPC | 7.72605 | | POOL BALANCE | 170.32536 |
| TEHRI HEP | 5.82918 | | | |
| NATHPA JHAKRI HEP | 0.24777 | | | |
| | | | | |
| Total | 170.57538 | : | Total | 170.57538 |



Case Study (SR)





- 12th Dec 2008
 - Period of Congestion: 0500 – 0600 Hrs
 - Congested Corridor: Total import to SR
 - TTC to SR reduced from 4000 MW to 3600 MW
 - Total provisional requisition: 1430 MW
 - Total trades cleared: 1091 MW
 - Market split into NEW Grid and SR Grid
 - MCP [IEX website]:
 - NEW Grid: Rs. 4.80 per kWh
 - SR Grid: Rs. 6.00 per kWh
 - Cost of Transmission discovered
 - Rs. 1.20 per kWh
- Congestion after 12th Dec 08
 - Foggy conditions in Talcher area

STOA (Bilateral) - SRLDC - Nodal RLDC



Experience of Congestion in NR : Yr 2009


- Backlog in capacitor installation & Critically low voltage in grid
- Poor South-west monsoon in NR, moderate-good rains in West/East
- Multiple transmission line outage due to tower damage
- Forced Outage due to emergency (400/220 kV Mandola S/S)
- Planned outage of transmission lines to facilitate construction
- Several incidents of multiple element outage
- Limited augmentation in transmission capacity




- Poor Southwest monsoons
- Heavy demand on account of weather beating load in urban areas and pumping load in rural areas
- Injection from other regions
- Restrictions on interregional open access imposed to arrest further deterioration of voltage

Load vs voltage in Delhi


Increase in Demand above 4000 MW




**Heavy Reactive Power Demand at Mainpuri
MW/MVAR Loading of ICTs on 4th August 2009**



**Heavy Reactive Power Demand at Kaithal
MW/MVAR Loading of ICTs on 4th August 2009**







**Heavy Reactive Power Demand at Meerut
MW/MVAR Loading of ICTs on 4th August 2009**




**Cascade tripping leading to
loss of around 1200 MW load
in Punjab system was experienced
on 10th June-2007**

**primarily on
account of heavy drawal at
critically low voltage**




Voltage profile subsequent to N-1 contingency

Voltage Profile during Tripping of Fact on 400 kV Kanpur - Ballabgarh at 11:02 hrs and Tripping of 765 kV (Charged at 400 kV) Anpara Unnao at 11:07 hrs



Voltages Observed After 400 kV Kanpur-Ballabgarh-Fact Outage & 400 kV Anpar-Unnao Outage



10th June 2009

11:02 hrs


FSC of 400 kV Kanpur-Ballabgarh tripped

After 5 minutes (11:07 hrs)


765 kV @ 400 kV Anpara-Unnao tripped

**In 2008-09
NR States have installed less than
10 % of the 6714 MVAR capacitor
Requirement**

**Synchronous Condenser Mode of Tehri HEP
on 4-Aug-2009**



**Synchronous Condenser Mode of Tehri HEP
on 3-Aug-2009**



**Tehri unit 4 was operated on
Synchronous condenser mode**

**10 kV improvement in voltage
observed at 400 kV Meerut**

Active Power consumption: 7-8 MW

Tower damage: Northern Region

| | Name of Line | Tripping time/date | Reasons of tripping |
|---|---------------------------------|---------------------|--|
| 1 | 400 kV Ballabgarh-G.Noida | 1551 hrs / 10.05.09 | 6 Nos. D/Ckts Towers (loc.no.70 to 75 , 4nos. A type , 1no.B type & 1 no.C type) damaged |
| 2 | 400 kV Ballabgarh-Maharani Bagh | 1551 hrs / 10.05.09 | At the same D/Ckts towers as above. |
| 3 | 400 kV Allahabad-Mainpuri-1 & 2 | 1851 hrs / 11.05.09 | 5 Nos. D/Ckts Towers (loc.no.798 to 802 , 5nos. A type) damaged (2 towers at 1st section and 3 towers at stub level). |
| 4 | 400 kV Dadri-Mandola-1 | 2128 hrs/ 19.05.09 | 2 Nos. D/Ckts Towers (loc.no.32 to 33 , DA type) damaged |
| 5 | 400 kV Dadri-Mandola- 2 | 2128 hrs/ 19.05.09 | At the same D/Ckts towers as above. |
| 6 | 400 kV Kanpur- Ballabgarh | 2129 hrs/ 19.05.09 | Insulator hardware fitting of B-Phase at loc.no. 928 (suspension tower,Yamuna River x-ing tower) |
| 7 | 400 kV Kanpur-Ballabgarh | 1736 hrs/ 28.05.09 | 3Nos. S/ Ckts Towers (loc.no.455 to 457 , 3nos. A type) damaged |

Tower damage: Northern Region

| | UPPCL Lines | | |
|----|----------------------------------|------------------------|--|
| 1 | 400 kV Unnao-Bareilly-1&2 | 2310 hrs / 10.05.09 | 2 Nos.D/Ckt Suspention Towers (loc.no.700 to loc.no.701) damaged (1 towers at middle section and 1 tower at stub level). |
| 2 | 220 kV Bareilly- Dohna-C.B. Gunj | 2302 hrs / 10.05.09 | 1 Nos. Tower(loc.no.15- Type A+5) damaged(twisted) |
| 3 | 220 kV Sitapur -Shahjahanpur | 2310 hrs/ 10.05.09 | 1No. Tower damaged. |
| 4 | 220 kV Merrut(PG)- Shatabdinagar | 2057 hrs/ 19.05.09 | 3Nos. D/C Towers (loc.no.63,64 &75) damaged. |
| 5 | 220 kV Shatabdinagar-Modipuram | 2057 hrs/ 19.05.09 | at the same D/Ckts towers as above. |
| 6 | 220 kV Orai - Kanpur | 0135 hrs/ 20.05.09 | 9 Nos. towers damaged. |
| 7 | 220 kV Orai - Parichha ckt-1 | 1710 hrs/ 28.05.09 | 3Nos. D/C towers (LOC.NO. 71,72,73) damaged. |
| 8 | 220 kV Orai - Mainpuri (UP) | 1710 hrs/ 28.05.09 | on same tower as above |
| 9 | 220 kV Orai - Parichha ckt-2 | 1710 hrs/ 28.05.09 | 3Nos. D/C towers (LOC.NO. 268,269,270) damaged. |
| 10 | 220 kV Orai - Parichha ckt-3 | 1710 hrs/ 28.05.09 | on same tower as above |

Tower damage: Northern Region

| RRVPLN Lines | | | |
|--------------|---|-----------------------|--|
| 1 | 220 kV S/Ckt Mandawar-Bharatpur | 1810 hrs/ 21.05.09 | 4Nos. Suspension towers and 1no. Tension tower damaged. |
| 2 | 132 kV S/Ckt Bharatpur-Nagar | 1810 hrs/ 21.05.09 | 5 Nos. towers damaged. |
| 3 | 132 kV S/Ckt Bharatpur-Nadbai | 1810 hrs/ 21.05.09 | 2 Nos. towers damaged. |
| PTCUL Lines | | | |
| 1 | 220 kV Bareilly - Pantnagar | 2259 hrs/ 10.05.09 | 1 Nos. Tower(loc.no.56- Type A) damaged. |
| DTL Lines | | | |
| 1 | 220 kV South of Wazirabad-Kashmiri Gate D/C | 1438hrs/ 22.05.09 | 3Nos. D/C Towers (loc.no.12,13 &14) twisted and damaged. |

Tower damage: Western & Eastern Region

| Western Region | | | |
|--|--------------------------------------|----------|-------------------|
| 1 | 400 kV Jabalpur – Itarsi D/C | 14/05/09 | 20 towers damaged |
| 2 | 400 kV Jabalpur Vindhaychal | 24/05/09 | 3 towers damaged |
| | Korba (NTPC)-Bhilai {PGCIL Line} | 6/6/2009 | 2 towers damaged |
| | Korba (W)-Bhilai {Chhattisgarh Line} | 5/6/2009 | 2 towers damaged |
| Other line outages reported in Eastern Region | | | |
| 1 | 220 kV Joda-Jamshedpur (DVC), | 18.05.09 | |
| 2 | 220 kV Bakreshawer- Bidhannagar D/C | 27.05.09 | |
| 3 | 220 kV Farakka-Lalmathiya (NTPC) | NA | 3 towers damaged |

400 kV Purnea-Malda D/C is also out on account of damage to tower

Multiple incidents on 15th Aug-09

- 400 kV Singrauli-Allahabad-I & 400 kV Singrauli-Anpara under S/D
- Following units went under planned/forced outage in NR
 - Rihand # 3, Singrauli # 1, Tanda # 1,
 - Kota # 1, 2, 5 & 7, Anpara # 1, Obra # 9 & 12
- 02:28 hrs, 15th Aug-09
 - Rihand # 1 & 2 tripped due to C.W. pump failure (revived by 0835 hrs)
- By 0600 hrs, 15th Aug-09
 - FSC on 400 kV Kanpur-Ballabgarh and Panki-Muradnagar out
- 1400-1500 hrs, 15th Aug-09
 - All six units (1500 MW) generation closed at Jhakri due to high silt
- 1650 hrs, 15th Aug-09
 - 400 kV Dadri-Muradnagar tripped on pole discrepancy at Muradnagar
- At 21:16 hrs, 15th Aug-09
 - Failure of auxiliary supply at Rihand
 - Rihand # 1 & 2 tripped
 - HVDC Rihand-Dadri Bipole tripped

List of generation loss > 500 MW in NR 01st Apr-08 to 31st Jul-09

| SI No. | Date | Time of disturbance | Affected Area | Type of Disturbance | Plants/Substations Affected | Loss of Generation (MW) |
|--------|-----------|---------------------|--------------------------------------|-----------------------------|---|-------------------------|
| 1 | 28-Apr-08 | 17:00 | Punjab | Loss of Generation | Ropar | 750 |
| 2 | 28-Apr-08 | 23:30 | Rajasthan | Loss of Generation | KTPS | 980 |
| 3 | 06-May-08 | 16:19 | Rajasthan | Loss of Generation | Suratgarh | 1200 |
| 4 | 07-May-08 | 16:16 | Rajasthan | Loss of Generation | Suratgarh | 950 |
| 5 | 14-May-08 | 23.41 | Rajasthan | Loss of Generation | Suratgarh | 1200 |
| 6 | 23-Jul-08 | 10:57 | Uttrakhand | Loss of Load and Generation | All generating units of Uttrakhand except Khatima | 741 |
| 7 | 27-Jul-08 | 13:25 | Uttrakhand | Loss of Load and Generation | All generating units of Uttrakhand except Khatima | 578 |
| 8 | 11-Aug-08 | 5.01 | NR Grid | Loss of Generation | Anpara | 600 |
| 9 | 22-Sep-08 | 02:01 | NR Grid | Loss of Generation | Dadri Thermal Dadri gas Vishnu pryag | 600 + 325 + 425 |
| 10 | 19-May-09 | 16.37 | Baspa, Jhakri, Abdullapur, Nallagarh | Loss of Generation. | Baspa, Jhakri, Abdullapur, Nallagarh | 1700 |
| 11 | 21-Jul-09 | 00.55 | Chamera | Loss of Generation | Chamera-I, Chamera-II | 840 |
| 12 | 24-Jul-09 | 20.06 | Haryana | Loss of Generation | Panipat | 900 |


List of simultaneous multiple transmission element tripping in NR from 01st Apr-08 to 31st Jul-09

| SI No. | Date | Time of disturbance | Affected Area | Type of Disturbance | Plants/Substations Affected | Loss of Generation (MW) |
|--------|-----------|-----------------------------|-----------------------|----------------------|-----------------------------|-------------------------|
| 16 | 21-Dec-08 | Night of 20th & 21st Dec 08 | NR Grid | Fog related tripping | 0 | 0 |
| 17 | 08-Apr-09 | 14.40 | Morak | Line tripping | Morak,Badod | NIL |
| 18 | 13-Apr-09 | 23:47 | Bawana | Line Tripping | Bawana | NIL |
| 19 | 02-May-09 | 13.50 | Raibareilly | Bus Fault | Raibareilly | NIL |
| 20 | 03-May-09 | 02.20 | 400 kV Panki (UP) | Line & ICT Tripping | 400 kV Panki (UP) | NIL |
| 21 | 17-May-09 | 11.25 | J & K | Line Tripping | Heeranagar | NIL |
| 22 | 17-May-09 | 16.25 | J & K | Line Tripping | Heeranagar | NIL |
| 23 | 18-May-09 | 17.13 | Area Around Anpara | Line Tripping | Anpara | 200 |
| 24 | 19-May-09 | 21.12 | Delhi | ICT Tripping | Mandaula | NIL |
| 25 | 19-May-09 | 21.17 | Muradnagar | Multiple Tripping | Muradnagar | NIL |
| 26 | 19-May-09 | 21.28 | Delhi | Line Tripping | Dadri & Mandaula | NIL |
| 27 | 20-May-09 | 15.18 | Area Around Anpara | Line Tripping | Anpara | 200 |
| 28 | 04-Jun-09 | 1754 | Meerut (PG)Substation | Line Tripping | Meerut (PG)Substation | NIL |
| 29 | 10-Jun-09 | 11.02 hrs /11.08 hrs | NR | FACT/Line outage | 0 | NIL |
| 30 | 26-Jun-09 | 06.30 | Delhi | Dead Bus at Mandaula | Mandola | NIL |

Transmission Outage to facilitate construction

- Stringing of HVDC Balia-Bhiwadi
 - 400 kV Agra-Bassi- II & III for 2 days
 - 400 kV Mainpuri-Ballabgarh D/C for 2 days
 - 220 kV Mainpuri-Harduaganj for 2 days
 - 132 kV Mainpuri-Etah for 2 days
- Work related to Anpara-D
 - 400 kV Singrauli-Allahabad-I and Singrauli-Anpara for 24 days continuous since 01st Aug 09

STOA (Bilateral) - NRLDC -Nodal RLDC




Transmission Line loading in NR (July-09)

| Transmission line Utilization in Northern Region (during the month of July-09) | | | | | | | | | |
|--|---------------------------------|------------------------|------------------------|------------------|-------------------|--------------------|--------------------|--------------------|----------------------------|
| S No. | Transmission line | Maximum Powerflow (MW) | Average Powerflow (MW) | Line length (km) | Conductor type | Design Capacity MW | Maximum/Design (%) | Average/Design (%) | Line Load factor = Avg/Max |
| | | A | B | C | D | E | F = A/E | G = B/E | B/A |
| 1 | 765 kV @ 400 kV Gwalior-Agra-I | 748 | 341 | 128 | Quad Bersimis | 1100 | 68% | 31% | 0.46 |
| 2 | 400 kV Muzaffarpur-Gorakhpur-II | 701 | 519 | 261 | Quad Moose + TCSC | 900 | 78% | 58% | 0.74 |
| 3 | 400 kV Panki-Muradnagar S/C | 502 | 378 | 395 | Twin Moose + FSC | 664 | 76% | 57% | 0.75 |
| 4 | 400 kV Kanpur-Ballabgarh S/C | 590 | 459 | 386 | Twin Moose + FSC | 639 | 92% | 72% | 0.78 |
| 5 | 400 kV Abdullapur-Bawana-I | 432 | 185 | 167 | Triple Snowbird | 605 | 71% | 31% | 0.43 |
| 6 | 400 kV Gorakhpur-Lucknow-II | 510 | 355 | 246 | Twin Moose | 515 | 99% | 69% | 0.70 |
| 7 | 400 kV Singrauli-Lucknow S/C | 423 | 341 | 409 | Twin Moose | 515 | 82% | 66% | 0.81 |
| 8 | 400 kV Singrauli-Kanpur S/C | 457 | 376 | 400 | Twin Moose | 515 | 89% | 73% | 0.82 |
| 9 | 400 kV Singrauli-Allahabad-I | 506 | 367 | 224 | Twin Moose | 515 | 98% | 71% | 0.72 |
| 10 | 400 kV Agra-Ballabgarh S/C | 530 | 337 | 181 | Twin Moose | 515 | 103% | 65% | 0.64 |


Northern Region transmission system utilization was significantly high in July-09

Inter-regional Import by Northern Region

Inter-regional Import by NR- Duration Curve for JULY-2009






21 Zones and 37 Flowgates in NR



RLDCs have to ensure integrated operation of the grid and schedule in accordance with contracts

Declaration of transfer capability in advance is only a transparent mechanism for executing the mandate




Types of congestion in Indian context

- 3 / 2 / 1 month (s) ahead – advance
- First come first served
- Day ahead PX
- Day ahead bilateral
- Contingency transaction
- Real time

Causes of congestion

- Inadequate transmission – including outages
- Inadequate reactive support
- Weather diversity, seasonal demand variation
- Skewed generation availability – monsoon, planned / forced outages
- Uneven purchasing power of utilities in a shortage scenario
- Compulsion to meet load at all costs (agriculture, festival, election etc.) – Aggressive buying
- Economy (cheaper generation to replace costlier generation)
- Inflated sale / purchase requirement – Pseudo congestion
- Inter play with UI mechanism – Bids based on anticipated UI price



Scenarios

4D

3D 1S

2D 2S

1D 3S (Congestion)


4S



Congestion - Power Exchange


- No congestion till onset of severe winter
- Winter
 - Since 12th December 2008
 - Congestion for import to SR
 - Failure of monsoon in SR
- Summer / monsoon
 - Congestion for import to NR
 - Aggressive buying by utilities in NR to meet weather beating / agriculture load

Seasonal Impact – Collective Transactions through PX



Congestion Management in Power Exchange

Daily high of Market Clearing Price (MCP) on IEX



Concerns-1

- Wide range of permissible frequency band
 - Significant interplay of frequency and voltage in a large grid
- 'UI' considered as an infinite source / sink
- Limited voluntary participation by utilities for congestion management in real-time
 - Primary response, Reactive Support
- Availability norm falling short of ensuring Dependability
 - Outage of complete power station
 - Outage of complete EHV substation

Concerns-2

- Changes in long-term allocations
- Uncertainties in planned outages of shared resources
- Medium-term inadequacies in transmission/generation
 - Open Loops, Switching arrangement
- Safety net
 - Relay settings/ behavior:
 - Credible N-1 contingency getting converted into simultaneous multiple outages in real-time
- Frequent large scale contingencies
 - Fog, Widespread rains, Cyclone, Silt
 - Limited support from online tools in case of fast events

Suggestions for improving transfer capability-1

- installation of shunt capacitors in pockets prone to high reactive drawal & low voltage
- strengthening of intra-state transmission and distribution system
- improving generation at load centre based generating stations by R&M and better O & M practices
- avoiding prolonged outage of generation/transmission elements
- reduction in outage time of transmission system particularly those owned by utilities where system availability norms are not available

Suggestions for improving transfer capability-1

- minimising outage of existing transmission system for facilitating construction of new lines
- expediting commissioning of transmission system-planned but delayed execution
- enhance transmission system reliability by strengthening of protection system
- strengthening the safety net- Under voltage load shedding schemes, system protection schemes

Conclusion

- It is impossible to plan / design a large congestion-free system
- Mild / occasional congestion indicates optimum investment in transmission
- Regular congestion indicates inadequacy
 - Generation
 - Transmission
 - Reactive compensation
- Utilization of congestion revenue to relieve congestion

Thank You for your attention !



Narrowing Permissible Frequency Range in Indian Electricity Grids

Meeting of the Coordination Forum
17th August 2009



FREQUENCY & FREQUENCY DURATION CURVE

DATE : 27/09/98 Sunday




FVI : 68.38

STD : 0.3

AVG. Freq : 52.6 Hz

Max. Freq : 53.3 Hz

Min Freq : 51.4 Hz




**POWER GRID CORPORATION OF INDIA LTD.
SOUTHERN REGIONAL LOAD DESPATCH CENTRE**



FREQUENCY ANALYSIS FOR


24-04-2002

Wednesday




| Frequency Variation based on data integrated over ONE minute interval | | | | | | | | |
|---|---------------|--------------|----------------------------|------------|-------------|------------------------------------|------------------------|--------------|
| | <48.0 | 48.0 & <48.5 | 48.5 & <49 | 49 & <49.5 | 49.5 & <50 | 50 & <50.5 | 50.5 & Above | |
| Minutes | 1396 | 44 | 0 | 0 | 0 | 0 | 0 | |
| In % | 96.9 | 3.1 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| Average Frequency over the day: | | 47.82 | Standard Deviation: | | 0.08 | Frequency Variation Index : | | 47.70 |
| | Instantaneous | | | | | | Quarter Hourly Average | |
| | Freq | Time | | | | | Freq | Time |
| Max | 48.31 | 06:01 | Max | 47.97 | 05:15 | | | |
| Min | 47.69 | 18:36 | Min | 47.75 | 13:45 | | | |

Daily Max & Min Frequency in NR




Daily Frequency Fluctuations in NR




Daily Max & Min Frequency in ER

Maximum & Minimum in ER/NEW Grid From 1998 Onwards




Daily Frequency Fluctuations in ER

Frequency Fluctuations in ER/NEW Grid 1998 Onwards




Daily Max & Min Frequency in SR

MAX & MIN FREQUENCY FOR SR GRID FROM APRIL-01 ONWARDS



Daily Frequency Fluctuations in SR

FREQUENCY FLUCTUATIONS IN SR GRID APRIL-2001 ONWARDS



Frequency Profile – India & Neighbors

| % of Time frequency (f) | India – NEW Grid | India – SR Grid | Pakistan | Sri Lanka | Nepal | Bhutan |
|-------------------------|------------------|-----------------|----------|-----------|-------|--------|
| $f < 49.0$ | 7 | 11 | 0 | 0 | 1 | 7 |
| $49.0 < f < 49.5$ | 49 | 68 | 20 | 0 | 18 | 49 |
| $49.5 < f < 49.8$ | 26 | 14 | 33 | 16 | 35 | 26 |
| $49.8 < f < 50.2$ | 16 | 6 | 40 | 81 | 30 | 16 |
| $50.2 < f < 50.5$ | 2 | 1 | 7 | 2 | 15 | 2 |
| $f > 50.5$ | 0 | 0 | 0 | 0 | 1 | 0 |

Source: SAARC Task Force on Grid Interconnections amongst SAARC members (Data for 2008 -09)

Frequency & Reactive Power

- Correlation between frequency and reactive power
 - Studied using real time SCADA data in NR
- Summary
 - 1% fall in frequency results in 6% to 12% increase in reactive power
 - One Hz change in frequency translates into 8000 to 10000 MVAR, considering an All India reactive power requirement of approx 60000 MVAR

Source: Reactive Power and System Frequency Relationship: A Case Study


- CBIP 7th International R&D Conference, Feb 2009

Frequency Response Characteristics

- Study conducted using real time SCADA data in NR and SR Grids
- Summary
 - NR Grid: Average 678 MW/Hz
 - SR Grid: Average 1020 MW/Hz
 - NEW Grid: Approx. 1800 MW/Hz
- Tightening of frequency band by 0.3 Hz translates into approx. 540 MW in NEW Grid and approx. 306 MW in SR Grid

Source: Frequency Response Characteristics of an Interconnected Power System – A Case Study of Regional Grids in India

Projected All India Capacity



Source: CEA

Projected Power Supply Position by 2012

| Period | Peak Demand (MW) | Peak Met (MW) | Deficit / Surplus (MW) | Deficit / Surplus (%) |
|---------|------------------|---------------|------------------------|-----------------------|
| 2011-12 | 152746 | 152899 | 153 | 0.1 |

| Period | Energy Req (MU) | Energy Avail (MU) | Deficit / Surplus (MU) | Deficit / Surplus (%) |
|---------|-----------------|-------------------|------------------------|-----------------------|
| 2011-12 | 968659 | 1010346 | 41687 | 4.3 |

Demand as per 17th EPS

Source: Power Scenario at a Glance, July 2009, CEA

CERC Order on ABT Dated 4th Jan 2000

"5.9.8 Another point for consideration is whether charges for overdrawal should be the same at 49.0 Hz and even below 49.0 Hz. It should be noted that the declared frequency in India is 50 Hz. An integrated power system should operate with a grid frequency hovering around 50 Hz. In practice however, the frequency range in India has been 48.5 Hz to 50.00 Hz. This is not desirable for achieving interconnected/integrated operation of the grid. With the additions to generation capacities, it is hoped that there may not be a drop below 49 Hz.

..... In fact the attempt should be to further narrow down the range with more generating capacities coming up and redundancy created."

Need for Tightening the Freq Band (1)

- Operation of very large grid
 - **Reliable & Secure operation**
 - Disturbances in one area can propagate
 - **Enhance grid security**
- Influence of frequency on
 - **Voltage**
 - One Hz change results in about 8 KV change at 400 KV level
 - **Reactive power**
 - 1% decrease in frequency causes 6% to 12% increase in MVAR
 - **Line loadings**
 - One Hz change may result in line flow variations of the order of 1000 MW across regions
 - May lead to congestion
 - **Overfluxing of Transformers**
 - Low frequency and high voltage combination

Need for Tightening the Freq Band (2)

- IEGC Clause 6.4.7
 - *“Provided that the States, through their SLDCs, shall always endeavour to restrict their net drawal from the grid to within their respective drawal schedules, whenever the system frequency is below 49.5 Hz”*
 - Encourage demand side management, “Negawatts”
- Encourage implementation of IEGC Clause 6.4.8
 - *“The SLDCs/STUs shall regularly carry out the necessary exercises regarding short-term demand estimation for their respective States, to enable them to plan in advance as to how they would meet their consumers’ load without overdrawing from the grid”*
 - Encourage balanced portfolios
- IEGC Clause 6.4.11
 - *“When the frequency falls below 49.5 Hz, the generation at all ISGS (except those on peaking duty) shall be maximized, at least upto the level which can be sustained, without waiting for an advise from RLDC.”*
 - Encourage voluntary despatch of costly stations below 49.5 Hz



Need for Tightening the Freq Band (3)

- Defense Mechanism
 - Presently first stage at 48.8 Hz
 - Frequent excursions below 49 Hz & operation of UFRs
 - UFRs bypassed, security compromised
 - Operation in a tightened frequency band and planned load shedding would ensure relief through UFRs is always available, enhancing grid security
- Primary Response
 - Chicken and egg situation
 - Large frequency variations making implementation of FGMO difficult
 - Tightened frequency band to facilitate implementation of FGMO

Need for Tightening the Freq Band (3)

- Near Future
 - Commonwealth Games 2010
 - Synchronization of SR Grid with NEW grid by 2012
 - Interconnections with SAARC member countries envisaged
- International practice
 - Operation in narrow frequency band only
 - Nordic Area: 49.9 to 50.1 Hz
 - UCTE Europe Continental: 49.8 to 50.2 Hz
 - US:
 - Eastern Interconnection: 59.95 to 60.05 Hz
 - Western Interconnection: 59.856 to 60.144 Hz

Secure Operation of Very Large Grid



Larger the footprint.....

..... More the complexities involved

Road Map

- Present
 - April 2009: 49.2 to 50.3 Hz
- Gradual narrowing
 - Jan 2010: 49.5 to 50.3 Hz
 - Jan 2011: 49.8 to 50.2 Hz

NLDC

Thank You !!