

**CENTRAL ELECTRICITY REGULATORY COMMISSION**  
**4<sup>th</sup> Floor, Chanderlok Building, 36 Janpath, New Delhi- 110001**  
**Ph: 23753942 Fax-23753923**

Petition No. 303/TT/2013

Date: 6.6.2014

To  
The Deputy General Manager,  
Power Grid Corporation of India Limited,  
Saudamini, Plot No. 2,  
Sector-29, Gurgaon-122001

Subject: Transmission Tariff for (1) 765/400KV, 1500 MVA ICT-1 along with associated bays at Jabalpur Pooling S/S (New) and (2) 400 KV D/C (Quad) Jabalpur Pooling S/S (New)-Jabalpur (Existing) S/S T/L along with associated bays under Transmission System for Phase-1 Generation projects in Orissa-part B in Western Region

Sir,

Please furnish the following information on affidavit, with advance copy to respondents/ beneficiaries, latest by 27.6.2014:-

- (a) Actual date of commercial operation of the assets covered in the petition;
- (b) Capital cost benchmarking date;
- (c) Documentary proof for ROW problem;
- (d) Norms adopted by the petitioner along with justification, in respect of cost for associated allied works and mandatory spares in respect of the following items:-
  - (i) Total sub-station equipments;
  - (ii) Structure for switchyard;
  - (iii) Bus bars/ conductors/ insulators
  - (iv) Control, Relay & Protection panel
  - (v) Switchgear
  - (vi) Outdoor lighting
  - (vii) Emergency DG set
  - (viii) Auxiliary System
  - (ix) PLCC
  - (x) Hardware fittings
  - (xi) Total transmission line material
  - (xii) Conductor
- (e) Reasons for huge variation in cost in respect of the following:
  - (i) Asset-1: Total preliminary work and land and total civil works
  - (ii) Asset-2: Total preliminary work and total civil works.

- (f) Values of indices as on the date of investment approval, date of order and date of commencing to arrive at reasons for variation of hard cost;
- (g) The details of other parts of the scheme and their commissioning schedule;
- (h) How the ICTs were commissioned, i.e. which lines were used for their charging and how these ICTs will be useful (loading) if other lines, namely Dharamjaygarh-Jabalpur is not commissioned?
- (i) Status of IPPs and their commissioning schedule for which their system was planned.

Yours faithfully,

Sd/-  
(Dr. P.K. Sinha)  
A C (Legal)