

Procedure adopted by POSOCO to calculate TTC/ATC

Input Data for Base Case Preparation

Network Topology:

- As per network data obtained from CTU and STUs.
- New transmission elements considered only after commissioning of that asset and duly considering their reliability during initial period.

Unit Availability:

- As per the maintenance schedule finalized by RPC.
- New generating units considered only after commissioning of the new units and duly considering their reliability during initial period.

Coal Fired Thermal Despach:

As per the anticipated ex-bus generation of the thermal generating units

Gas/ Nuclear Despach:

As per past trend of Plant Load Factor available

Hydro Despach:

- As per the past trend available at RLDCs/ SLDCs.
 - The day corresponding to the median value of daily consumption of the same month last year would be chosen.
 - The current inflow pattern is also considered.
- **Reactive power capability of generating units:**

- As per the generator capability curve or based on the assumption recommended in CEA’s Manual on Transmission Planning Criteria.
- **Nodal MW demand :**
 - As per the anticipated load provided by SLDCs or Load Generation Balance Report (LGBR) prepared by CEA or past trend available at RLDCs/ NLDC.
- **Nodal MVAR demand:**
 - As per the anticipated power factor provided by SLDCs.

Input Data and Source

S No.	Input Data	Suggested Source
1	Planning Criteria	Manual on Transmission Planning Criteria issued by CEA
2	Network Topology	Existing network with full elements available Planned outages during the entire assessment period
3	Transmission line limits	Minimum of thermal limit, stability limit and voltage limit
4	Thermal unit availability	Load Generation Balance report, Maintenance schedule
5	Thermal despatch	Ex bus after deducting the normative auxiliary consumption Output could be further discounted by the performance index of generating units of a particular size as compiled by CEA
6	Gas based thermal despatch	Past trend

7	Hydro despatch	Peak and off peak actual hydro generation on median consumption day of same month last year The current inflow pattern to be duly accounted
8	Load	Anticipated load
9	Credible contingencies	Planning criteria

Power System model considered for simulation studies

- EHV transmission network normally modelled down to 132 kV
- All generating units greater than 50 MW and connected at 132 kV and above are modelled
- Load is generally lumped at 132 kV or below
- Separate base cases are prepared for calculating the
 - export and import capability corresponding to both peak and off- peak load

TTC Assessment

- Total Transfer Capability between two areas assessed by
 - increasing the load in the importing area and increasing the generation in the exporting area or vice versa till the constraints are hit for a credible contingency.

Limiting constraints for various corridors

- Thermal limit under N-1 hit for most of the corridors
 - ER-NER: 220 kV Salakati-BTPS-Agia section
 - WR-SR: 400 kV Parli-Solapur section
 - S1-S2 : 400 kV Kolar-Hosur section
 - ER-SR : HVDC Talcher-Kolar capacity
 - Punjab: 400/220 kV ICTs/220 kV intra state system
 - ER-NER: 400kV Farakka-Malda section

- Thermal limit under normal operating condition
 - WR-NR: 400kV Singrauli-Anpara S/C leading to restrictions on HVDC Vindhychal
 - India-Bangladesh: 400kV Farakka-Behrampur S/C leading to restriction on HVDC Bheramara

Credible contingencies considered while assessing TTC

- Outage of single transmission element (N-1) in the transmission corridor or connected system
- Outage of a largest unit in the importing control area station
- Violation of grid voltage operating range
- Violation of transmission element loading limit in n-1 contingency case
- Violation of emergency limit in the n-1-1 contingency case
- Stability under n-1-1 contingency of a temporary single phase to ground fault on a 765 kV line close to the bus or a permanent single phase to ground fault on a 400 kV line close to the bus
- Angular difference of 30 degrees between adjacent buses under n-1 contingency

Transmission Reliability Margin (TRM)

- Two percent (2%) of the total anticipated peak demand met in MW of the control area/group of control area/region (to account for forecasting uncertainties)
- Size of largest generating unit in the control area/ group of control area/region.